



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 4007977
Permit # 01601-2019UPG
Request Rec'd 08/23/2019
Amended Date
Approval Date 8/26/2019 DS
Permit Expires 2/26/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: HPT TA Properties, LLC 24601 Center Ridge Road Westlake, OH 44145 Contact: Rob Porges (440) 808-7268	(2) <u>FACILITY</u> - name and address where tanks are located: TA Operating LLC 505 Trucker Lane R.R. #7 Bloomington, IL 61701 Contact: Lee Folkens (440) 808-7368
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 3, 4, 5, 6, 7) - 20,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 3, 4, 5, 6, 7) Piping - PARTIAL Fiberglass Double Wall Ameron Dualoy 3000/L to accomodate new dispenser sumps, (TK # 3, 4, 5, 6, 7) Piping - Shear Valves, (TK # 3, 4, 5, 6, 7) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 3, 4, 5, 6, 7) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Installation of new Under dispenser containment sump
Removal of (16) sixteen existing Under dispenser containment sumps
Installation of (16) sixteen Bravo under dispenser containment sumps.
Rework existing 2" primary dualoy fiberglass into sumps with 3 inch Dualoy secondary containment fiberglass piping. Install new OPW flex hoses on primary and satellite line, install new OPW impact valves.
Project will be done in two phases. Phase one dispensers 5-8 which are fed from tank 1 and tank 5.


Phase two dispensers 1-14 which are fed from tanks 3, 4 and 5.
Reinstall existing dispenser sump sensor in all new UDC (16 locations)
Perform all required testing and inspections with the State fire Marshall.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Northern Indiana Mechanical, Inc.
3311 E. 15th Avenue
Gary, IN 46403

Contact Person: Mike Kiest
Phone: (219) 963-1640
Contractor Registration # IL292 Exp. 3/25/2021

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File