



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2005707
Permit # 01616-2019INS
Request Rec'd 08/23/2019
Amended Date
Approval Date 8/27/2019 DS
Permit Expires 2/27/2020

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Ryder Truck Rental, Inc. 16155 Park Row, Suite 140 Houston, TX 77084 Contact: Heather Melton (281) 647-8900 Ext. Opt. 3	(2) FACILITY - name and address where tanks are located: Ryder Transportation Service #0351 902 Route 83 Bensenville, IL 60106 Contact: Terence Clark (330) 644-8893 Ext. 17
---	---

(3) INSTALLATION OF TANKS:

(a) Number and size of tanks being installed: (TK # 13, 14) - 15,000

(b) Type of tank(s): (TK # 13, 14) Tank - Fiberglass Brine Filled Double Wall Containment Solutions

(c) Type of piping: (TK # 13, 14) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX from new tanks to new dispensers as shown in site plan, (TK # 13, 14) Piping - Ball Valves, (TK # 13, 14) Piping - Shear Valves, (TK # 13, 14) Piping - Flex Connector Steel, (TK # 13, 14) Piping - Single Wall STP/Tanktop Sump Petroleum Containment Inc. 4800 Series

(d) Product to be stored in each tank: (TK # 13, 14) - Diesel Fuel

(e) Type of leak detection being used:

Tank: (TK # 13, 14) Leak Detect - Tank - Automatic Tank Gauging Incon TS 550 with SCALD, (TK # 13, 14) Leak Detect - Tank - Hydrostatic Reservoir Sensors Interstitial Monitoring Incon TSP - HIS Brite

Piping: (TK # 13, 14) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection FE Petro STP-MLD-D, (TK # 13, 14) Leak Detect - Piping - Non-Discriminating Sump Sensor Interstitial Monitoring Incon in all submersible and dispenser sumps. NOTE: Sensors must shut down the submersible pump supplying that line upon detection of a leak per 175.640 a) 1)

(f) Corrosion Protection being used:

Tank: (TK # 13, 14) Corrosion Prot - Tank - Fiberglass Non-Corrosive

Piping: (TK # 13, 14) Corrosion Prot - Piping - Fiberglass Non-Corrosive

(g) Spill containment devices, piping and dispenser containment devices: (TK # 13, 14) Spill Contain Device - Double Wall Spill Bucket Franklin Fueling Systems Defender 705

(h) Overfill prevention devices: (TK # 13, 14) Overfill Prev Device - Overfill Drop Tube Valve Franklin Fueling Systems 708 Defender Series

(4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov by calling (217)785-1020.

(5) GENERAL REQUIREMENTS : There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut

off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.


(6) SPECIAL CONTINGENCIES :

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone: (815) 398-6250
Contractor Registration # IL1890 Exp. 4/12/2020

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File