



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Extended

<p align="center">FOR OFFICE USE ONLY</p> <p>Facility # 4021634 Permit # 00393-2019UPG Request Rec'd 03/05/2019 Amended Date Approval Date 3/5/2019 DS Permit Expires 3/5/2020</p>

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Martin & Bayley, Inc. P.O. Box 385 Carmi, IL 62821</p> <p>Contact: Landon Bayley (618) 382-2334 Ext. 248</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Huck's #175 601 Charleston Mattoon, IL 61938</p> <p>Contact: Tonya Durdel (217) 235-4214</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 3) - 15,000, (TK # 4, 5) - 5,000*
 - (b) Type of tanks:*
 - (c) Type of piping:*
 - (d) Product to be stored in each tank: (TK # 3, 4) - Gasoline, (TK # 5) - Diesel Fuel*
 - (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
 - (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
 - (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 3, 4, 5) Spill Contain Device - Double Wall Spill Bucket OPW 1C-3112D Edge, (TK # 3, 4) Spill Contain Device - Single Wall Spill Bucket OPW 1-2100*
 - (h) Overfill prevention devices: (TK # 3, 4, 5) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-410C*
 - (i) Manway accessible at grade:*
- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) SPECIAL CONTINGENCIES :** Replace all tanks fill spill containers, and drop tubes, repalce vapor return spill contianers on gasoline tanks. **NOTE: Our records do not indicate that there are any existing ball floats**

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p> <p>Neumayer Equipment Company, Inc. 5060 Arsenal Street</p>	<p>Contact Person: Jimmy Spiros Phone: (314) 772-4501</p>
--	---

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File