



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2021179  
Permit # 01658-2019UPG  
Request Rec'd 08/30/2019  
Amended Date  
Approval Date 9/3/2019 DS  
Permit Expires 3/3/2020

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>2590 W. Golf, LLC 5277 Trillium Blvd. Hoffman Estates, IL 60192</p> <p>Contact: Rick Heidner (630) 894-0099</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Former Shell Station 2590 W. Golf Road Hoffman Estates, IL 60169</p> <p>Contact: Rick Heidner (630) 894-0099</p>
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 6, 7) - 15,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 6, 7) Piping - Fiberglass Single Wall Piping Ameron for vent piping relocation , (TK # 6, 7) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX to replace the existing piping in the same piping trench , (TK # 6, 7) Piping - Other Steel Riser, (TK # 6, 7) Piping - Ball Valves , (TK # 6, 7) Piping - Shear Valves , (TK # 6, 7) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 6, 7) - Gasoline*
- (e) Type of leak detection being used:*
  - Tank: (TK # 6, 7) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 Plus with CSLD*
  - Piping: (TK # 6, 7) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root TLS 350 PLLD leak sensors, (TK # 6, 7) Leak Detect - Piping - Non-Discriminating Sump Sensor Interstitial Monitoring Veeder Root*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 6, 7) Spill Contain Device - Double Wall Spill Bucket Franklin Fueling Systems Defender 705*
- (h) Overfill prevention devices: (TK # 6, 7) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-410C*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : Installing Bravo B1000 dispenser sumps with new shear valves and flex connectors. Installing new overfill and overspill with new risers. New veeder root tls 350 plus with csld plld and float sensors. This replaces permit 01731-2018UPG which has expired. **NOTE: A removal permit for the piping must be submitted for per 175.300 k) 3)**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Anderson Pump Service, Inc.  
19659 South 97th Avenue  
Mokena, IL 60448

Contact Person: Steve Kryl  
Phone: (708) 478-6190  
Contractor Registration # IL002275 Exp. 5/21/2020

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File