



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 1025344
Permit # 01600-2019UPG
Request Rec'd 08/23/2019
Amended Date 09/09/2019 DS
Approval Date 8/26/2019 DS
Permit Expires 2/26/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Johnson Oil Company 1305 12th Avenue Rock Falls, IL 61071 Contact: Kathy Peugh (815) 625-6380</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Express Lane Gas & Food Mart 209 East North Avenue Stockton, IL 61085 Contact: Mary Lou Leitzen (815) 625-6380</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 11, 12) - 12,000, (TK # 13, 14) - 8,200*
 - (b) Type of tanks:*
 - (c) Type of piping: (TK # 11, 12, 13, 14) Piping - Other Steel Riser, (TK # 11, 12, 13, 14) Piping - Single Wall STP/Tanktop Sump Franklin Fueling Systems 4736 Series Polyethylene*
 - (d) Product to be stored in each tank: (TK # 11) - Diesel Fuel, (TK # 12) - Gasoline - Regular, (TK # 13) - Gasoline - Mid-grade, (TK # 14) - Gasoline - Premium*
 - (e) Type of leak detection being used:*
 - Tank: (TK # 11, 12, 13, 14) Leak Detect - Tank - Automatic Tank Gauging Incon TS 550 with SCALD*
 - Piping:*
 - (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
 - (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 11, 12, 13, 14) Spill Contain Device - Single Wall Spill Bucket Franklin Fueling Systems Defender 705*
 - (h) Overfill prevention devices: (TK # 11, 12, 13, 14) Overfill Prev Device - Ball Only Removed Ball Float Vent Valve, (TK # 11, 12, 13, 14) Overfill Prev Device - Overfill Alarm Incon TS-RAI*
 - (i) Manway accessible at grade:*
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

changing ATG to add positive shut down on STP sump sensors only **NOTE: System was installed prior to 2008**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Illowa Enterprises, Inc.
2703 4th Avenue
Moline, IL 61265

Contact Person: Rob Vyncke
Phone: (309) 762-1729
Contractor Registration # IL981 Exp. 5/1/2020

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File