



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

<p align="center">FOR OFFICE USE ONLY</p> <p>Facility # 6044324 Permit # 01411-2019UPG Request Rec'd 05/29/2019 Amended Date 09/16/2019 DS Approval Date 7/29/2019 DS Permit Expires 1/29/2020</p>

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Love's Travel Stops & Country Stores, Inc. P.O. Box 26210 10601 N. Penn Oklahoma City, OK 73120 Contact: Kyle Collins (405) 834-0311</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Love's Travel Stop #384 1900 S. State Route 127 Greenville, IL 62246 Contact: John Peterson (405) 302-6640</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3, 4, 5) - 20,000, (TK # 6) - 12,000, (TK # 7) - 8,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 1) - B-99, (TK # 2, 3, 4) - Diesel Fuel, (TK # 5, 6, 7) - Gasoline*
- (e) Type of leak detection being used:*
Tank:
Piping:
- (f) Corrosion Protection being used:*
Tank:
Piping:
- (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 1, 2, 3, 4, 5, 6, 7) Spill Contain Device - Single Wall Spill Bucket Franklin Fueling Systems Defender 705*
- (h) Overfill prevention devices: (TK # 1, 2, 3, 4, 5, 6, 7) Overfill Prev Device - Overfill Drop Tube Valve Franklin Fueling Systems 708 Defender Series*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

replacing spill buckets as well as drop tubes, will remove all existing ball floats on tanks
Changing so that does not require air testing lines as we did no work to lines.

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p> <p align="right">Contact Person: Jimmy Spiros</p>
--

Neumayer Equipment Company, Inc.
5060 Arsenal Street
St. Louis, MO 63139

Phone: (314) 772-4501
Contractor Registration # IL1502 Exp. 3/26/2020

Sincerely,



Daniel H. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File