



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**Amended**

**FOR OFFICE USE ONLY**

Facility # 5018544  
Permit # 01741-2019UPG  
Request Rec'd 09/13/2019  
Amended Date 09/16/2019 DS  
Approval Date 9/16/2019 DS  
Permit Expires 3/17/2020

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>MRH Corporation 702 South Washington Bunker Hill, IL 62014</p> <p>Contact: Mike Howald (618) 585-4514</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Bunker Hill Short Stop 702 South Washington Bunker Hill, IL 62014</p> <p>Contact: Mike Howald (618) 585-4514</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired: (TK # 7, 9) - 4,000, (TK # 8, 10) - 12,000*

(b) *Type of tanks:*

(c) *Type of piping:*

(d) *Product to be stored in each tank: (TK # 7, 8) - Gasoline, (TK # 9) - Dyed Diesel, (TK # 10) - Diesel Fuel*

(e) *Type of leak detection being used:*

*Tank:*

*Piping:*

(f) *Corrosion Protection being used:*

*Tank:*

*Piping:*

(g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 7, 8, 9, 10) Spill Contain Device - Single Wall Spill Bucket OPW 1-2200*

(h) *Overfill prevention devices: (TK # 8) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-410C*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

Replacing spill buckets as well.

**NOTE: Our records do not indicate that they have an existing drop tube, only an overfill alarm. No ball float existing either?**


**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Contact Person: Jimmy Spiros

Neumayer Equipment Company, Inc.  
5060 Arsenal Street  
St. Louis, MO 63139

Phone: (314) 772-4501  
Contractor Registration # IL1502 Exp. 3/26/2020

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File