



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 4012411
Permit # 01805-2019UPG
Request Rec'd 09/23/2019
Amended Date
Approval Date 9/23/2019 DS
Permit Expires 3/24/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Ports Petroleum Co., Inc. 1337 Blachleyville Road Box 1046 Wooster, OH 44691 Contact: Jason Hough (330) 264-1885</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Fuel Mart #787 1207 E. Southline Rd. Tuscola, IL 61953 Contact: Crystal Holmes (330) 804-9126</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 6) - 12,000, (TK # 7, 8, 9) - 15,000, (TK # 10) - 8,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 6, 7, 8, 9, 10) Piping - Flexible Double Wall OPW Flexworks from existing tanks to dispensers as shown in site drawing, (TK # 6, 7, 8, 9, 10) Piping - Chase Secondary Containment OPW AXP - 4" secondary chase piping, (TK # 6, 7, 8, 9, 10) Piping - Ball Valves, (TK # 6, 7, 8, 9, 10) Piping - Extractor Fitting Valves, (TK # 6, 7, 8, 9, 10) Piping - Shear Valves, (TK # 6, 7, 8, 9, 10) Piping - Flex Connector Steel, (TK # 6, 7, 8, 9, 10) Piping - Single Wall STP/Tanktop Sump Bravo B-407-RB*
- (d) *Product to be stored in each tank: (TK # 6) - Gasoline, (TK # 7, 8) - Diesel Fuel, (TK # 9) - Gasoline - Regular, (TK # 10) - Gasoline - Premium*
- (e) *Type of leak detection being used:*
- Tank:*
- Piping: (TK # 6, 9, 10) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root TLS 450 Plus 8590 DPLLD, (TK # 6, 7, 8, 9, 10) Leak Detect - Piping - Non-Discriminating Sump Sensor Interstitial Monitoring Veeder Root in all submersible and dispenser sumps NOTE: Sensors must shut down the submersible pump supplying that line upon detection of a leak per 175.640 a) 1), (TK # 7, 8) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection FE Petro STP-MLD-HCD*
- (f) *Corrosion Protection being used:*
- Tank:*
- Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 6, 7, 8, 9, 10) Spill Contain Device - Single Wall Spill Bucket OPW 1C-3101 Edge*
- (h) *Overfill prevention devices: (TK # 6, 7, 8, 9, 10) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-400C*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


(5) SPECIAL CONTINGENCIES : NOTE: Contractor is repiping the facility, therefore a removal permit will need to be obtained to remove the existing piping

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Lawrence Building Corporation
8401 Fritz Road
Fort Wayne, IN 46818

Contact Person: Nate Lawrence
Phone: (260) 469-8400
Contractor Registration # IL002416 Exp. 2/4/2021

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File