



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2017221
Permit # 01806-2019UPG
Request Rec'd 09/19/2019
Amended Date
Approval Date 9/23/2019 DS
Permit Expires 3/24/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: St. George Petro, LLC 2 East Lake St. Northlake, IL 60164 Contact: Michael Misseha (224) 432-7697	(2) <u>FACILITY</u> - name and address where tanks are located: Northlake Marathon 2 East Lake Street Northlake, IL 60164 Contact: Michael Misseha (708) 343-0201
---	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 7) - 18,000, (TK # 10) - 1,000*

(b) *Type of tanks:*

(c) *Type of piping:*

(d) *Product to be stored in each tank: (TK # 7) - Gasoline - Regular, (TK # 10) - E-85*

(e) *Type of leak detection being used:*

Tank:

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 7) Spill Contain Device - Single Wall Spill Bucket OPW 1C-2100C-PEVR*

(h) *Overfill prevention devices: (TK # 10) Overfill Prev Device - Overfill Drop Tube Valve OPW 61SOM-EVR*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Tank # 7 RUL replace belowgrade 5 gallon overspill with new OPW 1C2100C-PEVR 5 gallon overspill
Tanks # 10 E-85 Replace existing overfill drop tube with new OPW 61SOM -EVR drop tube for E-85

NOTE: No ball float listed in database for tank 10

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group
2422 Center Street


Contact Person: Robert Stenstrom

Rockford, IL 61108

Phone: (815) 398-6250

Contractor Registration # IL1890 Exp. 4/12/2020

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File