



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 7001927  
Permit # 01808-2019UPG  
Request Rec'd 09/23/2019  
Amended Date  
Approval Date 9/23/2019 DS  
Permit Expires 3/24/2020

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Valerie D. Millis, LLC 90 Old Golconda Rd. Golconda, IL 62938  Contact: Valerie D. Millis (618) 841-5064	<b>(2) FACILITY</b> - name and address where tanks are located:  Golconda Gas N Go 120 North Adams Street Golconda, IL 62938  Contact: Larry W. Millis (618) 841-5064
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 5) - 4,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 5) Piping - Flexible Double Wall OPW Flexworks from existing tank to new transition sump and then to new dispenser island as shown in site plan, (TK # 5) Piping - Single Wall Transition Sump Unknown Polyethylene*
- (d) Product to be stored in each tank: (TK # 5) - Diesel Fuel*
- (e) Type of leak detection being used:*

*Tank:*  
*Piping: (TK # 5) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection Red Jacket FX1D , (TK # 5) Leak Detect - Piping - Non-Discriminating Sump Sensor Interstitial Monitoring Veeder Root in submersible and dispenser sumps NOTE: Sensors must shut down the submersible pump supplying that line upon detection of a leak per 175.640 a) 1)*
- (f) Corrosion Protection being used:*

*Tank:*  
*Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : - New flexwork piping will be run from existing diesel tank sump to new transition sump with new proposed island dispensers and new canopy.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Robert Ellis & Sons

Contact Person: Mike Ellis

1703 North 7th Street  
Murphysboro, IL 62966

Phone: (618) 684-6026  
Contractor Registration # IL980 Exp. 3/23/2020

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File