



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2042550
Permit # 01811-2019UPG
Request Rec'd 09/20/2019
Amended Date
Approval Date 9/23/2019 DS
Permit Expires 3/24/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Walmart, Inc. 2101 Simple Savings Drive Bentonville, AR 727160745 Contact: (479) 204-0402	(2) <u>FACILITY</u> - name and address where tanks are located: Walmart Fueling Station #5352 801 N. Randall Rd. Batavia, IL 60510 Contact: Christopher Steward (479) 204-0402
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1, 3) - 20,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 3) Piping - Flexible Double Wall OPW Flexworks, (TK # 1, 3) Piping - Shear Valves, (TK # 1, 3) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 1, 3) - Gasoline*
- (e) *Type of leak detection being used:*
- Tank:*
- Piping: (TK # 1, 3) Leak Detect - Piping - EXISTING Non-Discriminating Sump Sensor Interstitial Monitoring Veeder Root NOTE: Sensors must shut down the submersible pump supplying that line upon detection of a leak per 175.640 a) 1)*
- (f) *Corrosion Protection being used:*
- Tank:*
- Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*


- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES** : The site currently has (3) dispenser sumps in a row. The middle sump is being used as a transition sump. We will be removing the middle sump and piping runs between dispensers on a removal permit. We will then install a new 4" chase pipe and pull new flexworks piping between the two sumps that will remain. We will be reusing the existing sump sensors, shear valves, and flex connectors.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone: (815) 398-6250
Contractor Registration # IL1890 Exp. 4/12/2020

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File