



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 4038972
Permit # 01836-2019UPG
Request Rec'd 09/25/2019
Amended Date
Approval Date 9/25/2019 DS
Permit Expires 3/25/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Guru Krupa Gas & Liquor 1601 Old State Road Mattoon, IL 61938</p> <p>Contact: Himanshu (Harry Amin) (217) 690-7855</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>S & H Gas & Liquor 1601 Old State Road Mattoon, IL 61938</p> <p>Contact: Himanshu (Harry) Amin (217) 234-7625</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 3) - 4,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 3) Piping - Flexible Double Wall A.P.T. Poly Tech S175SC from existing tank to dispenser. , (TK # 3) Piping - Other submersible pump, (TK # 3) Piping - Positive Shutoff Valves, (TK # 3) Piping - Shear Valves*

(d) *Product to be stored in each tank: (TK # 3) - Diesel Fuel*

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 3) Leak Detect - Piping - Non-Discriminating Sump Sensor Interstitial Monitoring Veeder Root in new diesel sump, a sensor already exists in the submersible sump. NOTE: Sensors must shut down the submersible pump upon detection of a leak per 175.640 a) 1)

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Contractors is replacing existing dispenser and product line.

NOTE: Per 175.450 f) 5) the dispenser shall be located 10 feet or more from any property lines or buildings

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Seneca Companies, Inc.
4140 East 14th Street PO Box 3360
Des Moines, IA 50313

Contact Person: Glen Davis
Phone: (816) 761-1270
Contractor Registration # IL598 Exp. 2/23/2020

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File