



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 1042306
Permit # 01904-2019UPG
Request Rec'd 10/03/2019
Amended Date
Approval Date 10/7/2019 DS
Permit Expires 4/7/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Love's Travel Stops & Country Stores, Inc. P.O. Box 26210 10601 N. Penn Oklahoma City, OK 73120</p> <p>Contact: Kyle Collins (405) 834-0311</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Love's Travel Stop #322 13477 Quality Drive Roscoe, IL 61073</p> <p>Contact: Ramsey Lohf (405) 834-0311</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1, 3) - 20,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 3) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX from transition sump by the tanks to master dispensers #20 & 21. Existing entry boots at the transition sump and dispenser sumps will not be disturbed. We will connect from the existing 3" FRP pipe in the sumps to the 2" LCX pipe with FRP reducers*
- (d) *Product to be stored in each tank: (TK # 1, 3) - Diesel Fuel*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES : NOTE: Site has existing sumps and sensors

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>Illinois Oil Marketing Equipment, Inc. 850 Brenkman Drive</p>	<p>Contact Person: Chris Epkins Phone: (309) 347-1819</p>

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File