



City of Chicago  
Department of Public Health  
333 South State Street, Room 200  
Chicago, IL 60604  
3127453152

## Revised

### Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Sul

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was i does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Divisio time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Chicago Public Schools 1 North Dearborn, Suite 950 Chicago, IL 60602  Contact: Robert Christlieb (312) 965-6434	<b>(2) FACILITY</b> - name and address where tanks a  Hanson Park Field House 5411 W. Fullerton Ave. Chicago, IL 60639  Contact: Robert Christlieb (312) 965-6434
--	---

### **(3) REMOVAL OF TANKS:**

- (a) Number and size of tanks being removed: (TK # 1) - 2,000*
- (b) Description/location of piping being removed:*
- (c) Product to be stored in each tank: (TK # 1) - Heating Oil*
- (d) Reason of tanks being removed:*
- (e) If tank(s) is leaking, indicate IEMA incident number:*
- (f) Date each tank was last used: (TK # 1) - 12/31/1973*

- (4)** The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. Thi or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal

### **(5) SPECIAL CONTINGENCIES :**

Expose top of tank. Look in tank for remaining liquids. Pump liquids from tank. Mointor gas inside tank for flammables. Excavate sides of tar offiste.

### **Site Plans**

### **(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

The Lighthouse Companies  
3120 Cottonwood Court  
Highland Park, IL 60035

Contact Person: Alan Levine  
Phone: (224) 619-4307  
Contractor Registration # IL002409 Exp. 6/19/201

Sincerely,

Shelly Bradley

cc: Storage Tank Safety Specialist  
Division File