



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2012720  
Permit # 01973-2019UPG  
Request Rec'd 10/15/2019  
Amended Date  
Approval Date 10/15/2019 DS  
Permit Expires 4/15/2020

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Faisal Siddiqui 1557 S. Central Ave. Cicero, IL 60804  Contact: (630) 841-8012	<b>(2) FACILITY</b> - name and address where tanks are located:  Citgo 1557 South Central Avenue Cicero, IL 60804  Contact: Asif Salam (630) 841-8012
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired: (TK # 5) - 12,000, (TK # 6, 7) - 8,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 5, 6) Piping - Other Steel Riser*

(d) *Product to be stored in each tank: (TK # 5, 6) - Gasoline, (TK # 7) - Diesel Fuel*

(e) *Type of leak detection being used:*

*Tank:*

*Piping:*

(f) *Corrosion Protection being used:*

*Tank:*

*Piping:*

(g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 5, 6) Spill Contain Device - Single Wall Spill Bucket OPW 1C-2100C-PEVR, (TK # 7) Spill Contain Device - Single Wall Spill Bucket OPW 1C-2115 DEVR*

(h) *Overfill prevention devices: (TK # 5, 6) Overfill Prev Device - Overfill Drop Tube Valve OPW 61SOP*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

Per third party inspection the (3) existing overspill manholes need to be replaced. Drop tubes are not up to spec on the Gasoline tanks

We will also be installing (2) INCON 3/4" Electrical entry boots inside of RUL submerge pump sump

**NOTE: No existing ball floats**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Contact Person: Robert Stenstrom

Stenstrom Petroleum Services Group  
2422 Center Street  
Rockford, IL 61108

Phone: (815) 398-6250  
Contractor Registration # IL1890 Exp. 4/12/2020

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File