



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 7017983
Permit # 01976-2019CAT
Request Rec'd 10/15/2019
Amended Date
Approval Date 10/15/2019 DS
Permit Expires 4/15/2020

Permit for INSTALLATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. A required job schedule for cathodic protection upgrade of underground storage tank(s) and piping must be submitted to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: NPWK, LLC 815 John Street, Suite 2 Evansville, IN 47713 Contact: Nicholas Hermann (812) 455-6451	(2) <u>FACILITY</u> - name and address where tanks are located: Junction General Store 11750 State Highway 1 Junction, IL 62954 Contact: Tina Naas (812) 455-6451
--	---

(3) UPGRADE, OR REPAIR OF CATHODIC PROTECTION SYSTEM:

(a) *Number and size of tanks having cathodic protection installed, upgraded, or repaired: (TK # 4) - 6,000*

(b) *Type of tanks:*

(c) *Type of piping:*

(d) *Product to be stored in each tank: (TK # 4) - Diesel Fuel*

(e) *Type of leak detection being used:*

Tank:

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping: (TK # 4) Corrosion Prot - Piping - Sacrificial Anode Flex Connector spike anode

(g) *NACE certified designer:*

(h) *Method of integrity assessment of tank(s) being used:*

(4) The owner must notify this Office when completion of cathodic protection upgrade has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for cathodic protection upgrade to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling 2177851020.

(5) **SPECIAL CONTINGENCIES** : Install corrosion protection on piping in Dispenser 1/2 sump.

(6) The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(7) PERSON, FIRM OR COMPANY PERFORMING WORK:

Hinderliter Construction & Maint., Inc.
3601 North St. Joseph Avenue
Evansville, IN 47720

Contact Person: Mark Hinderliter
Phone: (812) 425-4137
Contractor Registration # IL646 Exp. 4/2/2020

Sincerely,

Daniel H. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File