



City of Chicago  
Department of Public Health  
333 South State Street, Room 200  
Chicago, IL 60604  
3127453152

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174 issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Grand Mobil 527 S. Wells Street, Suite 700 Chicago, IL 60607  Contact: Peter Cacciatore (312) 264-6027	<b>(2) FACILITY</b> - name and address where tanks are located:  Grand Mobil 3601 W. Grand Avenue Chicago, IL 60651  Contact: Peter Cacciatore (312) 264-6027
-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 10,000, (TK # 2) - 6,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 2) Piping - Other Steel Riser*
- (d) *Product to be stored in each tank: (TK # 1) - Gasoline - Regular, (TK # 2) - Gasoline - Premium*
- (e) *Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices: (TK # 1, 2) Spill Containment Device - Single Wall Spill Bucket OPW*
- (h) *Overfill prevention devices: (TK # 1, 2) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-410C*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank For required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

Replacing Regular & Premium Spill container, riser, and droptube.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

B & K Equipment Company

Contact Person: Ed Angell

2939 175th Street  
Lansing, IL 60438

Phone: (708) 474-3344  
Contractor Registration # IL1207 Exp. 2/14/2020

---

Sincerely,

  
Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist  
Division File