



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**Amended**

<p align="center"><b>FOR OFFICE USE ONLY</b></p> <p>Facility # 3017407 Permit # 01113-2019UPG Request Rec'd 06/10/2019 Amended Date 10/17/2019 DS Approval Date 6/10/2019 DS Permit Expires 12/10/2019</p>
--

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Mac's Convenience Stores, LLC 550 Warrenville Rd., Suite 400 Lisle, IL 60532  Contact: Charlene Troyer (630) 800-6065</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Circle K #1394 5422 Farmington Rd. Peoria, IL 61604  Contact: Jon Schwindenhammer (309) 676-5859</p>
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 3) - 6,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 3) Piping - Ball Valves, (TK # 3) Piping - Flex Connector Steel, (TK # 3) Piping - Single Wall STP/Tanktop Sump OPW Fiberglass*
- (d) Product to be stored in each tank: (TK # 3) - Gasoline - Premium*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

Remove existing sump and instal new sump, also replace flex connecotr, ball valve, and STP Pump. Piping is flexible piping will be re-installed and re-install existing sump sensor. Work done to tnak #3, oringally applied for permit to do this work to tank #1. Amended permit to correct.


Applied for permit on the wrong tank, need to correct.

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>
---

Neumayer Equipment Company, Inc.  
5060 Arsenal Street  
St. Louis, MO 63139

Contact Person: Jimmy Spiros  
Phone: (314) 772-4501  
Contractor Registration # IL1502 Exp. 3/26/2020

Sincerely,

  
\_\_\_\_\_

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File