



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 4021968  
Permit # 02034-2019UPG  
Request Rec'd 10/21/2019  
Amended Date  
Approval Date 10/21/2019 DS  
Permit Expires 4/21/2020

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  University of Illinois Board of Trustees 1501 S. Oak Street Champaign, IL 61820  Contact: Bill Walsh (217) 333-9297	<b>(2) FACILITY</b> - name and address where tanks are located:  Willard Airport 1 Airport Road Savoy, IL 61874  Contact: Jeff Gooch (217) 244-8604
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 20, 21) - 4,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 20, 21) Piping - Fiberglass Double Wall*
- (d) Product to be stored in each tank: (TK # 20) - Gasoline - Regular, (TK # 21) - Diesel Fuel*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.


- (5) **SPECIAL CONTINGENCIES** : Removing existing UDC"s and installing new APT med bury dispenser sumps due to failed testing and customer request.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Seneca Companies, Inc.  
4140 East 14th Street PO Box 3360  
Des Moines, IA 50313

Contact Person: Glen Davis  
Phone: (816) 761-1270  
Contractor Registration # IL598 Exp. 2/23/2020

Sincerely,

---

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File