



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

<b>FOR OFFICE USE ONLY</b>
Facility # 2016778
Permit # 02039-2019ENT
Request Rec'd 10/22/2019
Amended Date
Approval Date 10/22/2019 DS
Permit Expires 4/22/2020

**Permit for HOTWORK/ ENTRY into Underground Storage Tank(s) for Petroleum and Hazardous Substances.**

Permission to enter underground storage tank(s) is hereby granted. Such tank entry shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Sonia Pump &amp; Mini Mart, Inc. 2340 W. 75th Street Woodridge, IL 60517  Contact: Harry Singh (630) 969-6696</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Marathon 2340 W. 75th Street Woodridge, IL 60517  Contact: Kapil Ahuja (630) 969-6646</p>
---	---

**(3) ENTRY OF TANKS:**

- (a) Number and size of tanks being entered: (TK # 5, 6) - 12,000, (TK # 7) - 10,000*
- (b) Type of tanks:*
- (c) Product to be stored in each tank: (TK # 5) - Gasoline - Regular, (TK # 6) - Diesel Fuel, (TK # 7) - Gasoline - Premium*
- (d) Manway accessible at grade:*

**(4)** The owner must notify this Office when completion of tank entry has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling 2177851020.

**(5) SPECIAL CONTINGENCIES** : Tank relining, lining inspection and entry permit work in reference to manways/manholes must abide by section 175.500.

Install three (3) 4" bung adaptors in three (3) UST's. Purge tanks to safe atmosphere. Cut openings in tanks for new bungs. Sandblast area and install bungs with 3/8" self-tapper bolts, AS9000 material and AB-310 resin/matting layup. Inspect for proper cure and coverage.

**NOTE: No welding can be done on tanks**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
<p>Armor Shield of Wisconsin 1875 Highland Court Slinger, WI 53086</p>	<p>Contact Person: Clayton Bennett Phone: (262) 644-6447 Contractor Registration # IL1707 Exp. 4/18/2020</p>

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File