



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
3127453152

FOR OFFICE USE ONLY

Facility # 2013506
Permit # 02043-2019UPG
Request Rec'd 10/22/2019
Amended Date
Approval Date 10/23/2019
Permit Expires 4/23/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Central Gas Real Estate, LLC 1754 N. Central Ave. Chicago, IL 60639</p> <p>Contact: Naif Alaskari (773) 469-9040</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Central Gas & Minimart 1754 N. Central Chicago, IL 60639</p> <p>Contact: Naif Alaskari (773) 836-7501</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 6) - 12,000, (TK # 7) - 7,000, (TK # 8) - 8,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 6, 7, 8) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX, (TK # 6, 7) Piping - Other Steel Riser, (TK # 6, 7, 8) Piping - Ball Valves, (TK # 6, 7, 8) Piping - Shear Valves, (TK # 6, 7, 8) Piping - Flex Connector Steel, (TK # 6, 7, 8) Piping - Single Wall STP/Tanktop Sump Bravo B-407-PP*

(d) *Product to be stored in each tank: (TK # 6) - Gasoline - Regular, (TK # 7) - Gasoline - Premium, (TK # 8) - Diesel Fuel*

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 6, 7) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection FE Petro STP-MLD-G, (TK # 6, 7, 8) Leak Detect - Piping - Non-Discriminating Sump Sensor Interstitial Monitoring, (TK # 8) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection FE Petro STP-MLD-D

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 6, 7, 8) Spill Contain Device - Double Wall Spill Bucket OPW 1C-3112D Edge*

(h) *Overfill prevention devices: (TK # 6, 7) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-400C, (TK # 8) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-4000*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

we are installing new fiberglass double wall piping,opw double wall spill buckets,drop tubes,bravo

dispenser sumps,bravo stp sumps and veedroot 208 sensors for stp and dispenser sumps

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

America Petropump Services LLC d/b/a Ampsco Services
4075 Fox Valley Center Dr., Unit 9
Aurora, IL 60504

Contact Person: Kiran Patibandla
Phone: (630) 649-8699
Contractor Registration # IL002420 Exp. 5/22/2021

Sincerely,



Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist
Division File