



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 1009417
Permit # 02072-2019UPG
Request Rec'd 10/28/2019
Amended Date
Approval Date 10/29/2019 DS
Permit Expires 4/29/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Jay Sadhima, LLC 120 N. Main Street Sandwich, IL 60548 Contact: (773) 595-1621</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Jay Sadhima, LLC 120 N. Main Street Sandwich, IL 60548 Contact: Ghanshyam Patel (773) 595-1621</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 6, 7) - 10,000, (TK # 9) - 2,000*
 - (b) Type of tanks:*
 - (c) Type of piping:*
 - (d) Product to be stored in each tank: (TK # 6) - Gasoline - Premium, (TK # 7) - Gasoline - Regular, (TK # 9) - Diesel Fuel*
 - (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
 - (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
 - (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 6) Spill Contain Device - Single Wall Spill Bucket OPW 1C-2100-DEVR, (TK # 7, 9) Spill Contain Device - Single Wall Spill Bucket Emco Wheaton A1004*
 - (h) Overfill prevention devices: (TK # 6, 7, 9) Overfill Prev Device - Overfill Alarm Veeder Root TLS 350R*
 - (i) Manway accessible at grade:*
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES** : Relocate TLS350R console to back room. Provide and install Veeder Root TLS350R overfill alarm and acknowledgement switch. Install Emco Wheaton spill containers on tanks RUL and Diesel. Install OPW 1C-2100 spill container on Premium tank that was installed by an unknown contractor without permit. All work is NOV related. **NOTE: All ball floats will be disabled**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Anderson Pump Service, Inc.
19659 South 97th Avenue
Mokena, IL 60448

Contact Person: Steve Kryl
Phone: (708) 478-6190

Sincerely,



Daniel H. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File