



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 3016990
Permit # 01956-2019UPG
Request Rec'd 10/10/2019
Amended Date 10/30/2019 DS
Approval Date 10/15/2019 DS
Permit Expires 4/15/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Malahee Petroleum, Inc. 8316 State Route 9 Bartonville, IL 61607 Contact: Sabry Malahee (312) 539-3771</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Bart Discount Tobacco & Gas 8316 South Route 9 Bartonville, IL 61607 Contact: Sabry Malahee (312) 539-3771</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 5, 6, 7) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 5, 6, 7) Piping - Other Steel Riser*
- (d) Product to be stored in each tank: (TK # 5) - Gasoline - Regular, (TK # 6) - Gasoline - Premium, (TK # 7) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank: (TK # 5, 6, 7) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 Plus with CSLD*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices: (TK # 5, 6, 7) Overfill Prev Device - Overfill Drop Tube Valve OPW 61SOP*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Making changes to summary of site work. Adding installation of 4" pipe risers at the vent extractors for grade level access. Changing overfill protection from ball float valves to drop tube overfill valve assemblies due to failed testing of the ball float valves.

NOTE: Ball floats to be disabled

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Total Petroleum Service Company
2421 Washington Road


Contact Person: Greg McCoy

Washington, IL 61571

Phone: (309) 694-8224

Contractor Registration # IL1079 Exp. 2/8/2020

Sincerely,

A handwritten signature in cursive script that reads "Daniel H. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File