



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2001185
Permit # 02105-2019UPG
Request Rec'd 11/01/2019
Amended Date
Approval Date 11/4/2019 DS
Permit Expires 5/5/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Pepper Construction Company 410 S Hager St Barrington, IL 60010 Contact: Donna Gaus (847) 975-9555	(2) <u>FACILITY</u> - name and address where tanks are located: Pepper Construction Company 410 South Hager Street Barrington, IL 60010 Contact: Steve Graber (847) 975-9555
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) Number and size of tanks being upgraded or repaired: (TK # 4) - 6,000

(b) Type of tanks:

(c) Type of piping: (TK # 4) Piping - Other Steel Riser

(d) Product to be stored in each tank: (TK # 4) - Gasoline

(e) Type of leak detection being used:

Tank:

Piping:

(f) Corrosion Protection being used:

Tank:

Piping:

(g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 4) Spill Contain Device - Single Wall Spill Bucket Emco Wheaton A1004

(h) Overfill prevention devices: (TK # 4) Overfill Prev Device - Overfill Drop Tube Valve Emco Wheaton A1100 Guardian

(i) Manway accessible at grade:

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Replace spill container, drop tube and riser due to drop tube being seized in the riser.

NOTE: No existing ball float

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Anderson Pump Service, Inc.
19659 South 97th Avenue


Contact Person: Steve Kryl

Mokena, IL 60448

Phone: (708) 478-6190

Contractor Registration # IL002275 Exp. 5/21/2020

Sincerely,

A handwritten signature in cursive script, reading "Daniel H. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File