



**City of Chicago**  
**Department of Public Health**  
 333 South State Street, Room 200  
 Chicago, IL 60604  
 3127453152

<b>FOR OFFICE USE ONLY</b>
Facility # 2023067
Permit # 02132-2019CAT
Request Rec'd 11/06/2019
Amended Date
Approval Date 11/6/2019
Permit Expires 5/6/2020

**Permit for INSTALLATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. A required job schedule for cathodic protection upgrade of underground storage tank(s) and piping must be submitted to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Norko, LLC          4400 W. North Avenue          Chicago, IL 60639          Contact: Tito Kandarappallil (847) 323-3109</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Amoco 5025          4400 West North Avenue          Chicago, IL 60639          Contact: Tito Kandarappallil (847) 323-3109</p>
--	--

**(3) UPGRADE, OR REPAIR OF CATHODIC PROTECTION SYSTEM:**

- (a) Number and size of tanks having cathodic protection installed, upgraded, or repaired: (TK # 1, 2) - 10,000, (TK # 3) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 1) - Gasoline - Non Ethanol, (TK # 2, 3) - Gasoline - Regular*
- (e) Type of leak detection being used:*  
*Tank:*  
*Piping:*
- (f) Corrosion Protection being used:*  
*Tank: (TK # 1, 2, 3) Corrosion Prot - Tank - Impressed Current Cathodic Protection*  
*Piping: (TK # 1, 2, 3) Corrosion Prot - Piping - Impressed Current Cathodic Protection*
- (g) NACE certified designer:*
- (h) Method of integrity assessment of tank(s) being used:*

**(4)** The owner must notify this Office when completion of cathodic protection upgrade has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for cathodic protection upgrade to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling 3127453152.

**(5) SPECIAL CONTINGENCIES :** Installing (8) Impressed Anodes on all Tanks and Lines

**(6)** The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

<b>(7) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Protanic, Inc. 658 North Progress Drive PO Box 80265 Saukville, WI 53080	Contact Person: Frank Grebas Phone: (262) 268-1150 Contractor Registration # IL1413 Exp. 9/26/2020

---

Sincerely,



Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist  
Division File