



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

| |
|--|
| <p align="center">FOR OFFICE USE ONLY</p> <p>Facility # 5006056 Permit # 02012-2019UPG Request Rec'd 10/17/2019 Amended Date 11/07/2019 DS Approval Date 10/21/2019 DS Permit Expires 4/21/2020</p> |
|--|

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

| | |
|--|---|
| <p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>ARC CKMST19001, LLC 106 York Road Jenkintown, PA 19046 Contact: Charlene Troyer (630) 800-6065</p> | <p>(2) FACILITY - name and address where tanks are located:</p> <p>Mac's Convenience Stores, LLC d/b/a Circle K #1213 1000 N. Springfield Virden, IL 62690 Contact: Charlene Troyer (630) 800-6065</p> |
|--|---|

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 3) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 3) Piping - Fiberglass Single Wall Piping Ameron , (TK # 3) Piping - Steel Single Wall Piping OmegaFlex DEF-Trac flexible stainless steel with heat trace, (TK # 3) Piping - Single Wall STP/Tanktop Sump Bravo B-407-RB*
- (d) Product to be stored in each tank: (TK # 3) - Gasoline - Regular*
- (e) Type of leak detection being used:*
Tank:
Piping: (TK # 3) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root TLS 350 PLLD leak sensors
- (f) Corrosion Protection being used:*
Tank:
Piping:
- (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 3) Spill Contain Device - Single Wall Spill Bucket OPW ISC-2100DEVR*
- (h) Overfill prevention devices: (TK # 3) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-410C*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Tank Tech repaired inside the existing tank by building a new inner tank. We are replacing old tank top components with new parts in the existing layout as before. Installing 5ft of new single wall fiberglass Ameron pipe to connect to existing pipe run.


Uploading line test results

| |
|---|
| (6) PERSON, FIRM OR COMPANY PERFORMING WORK: |
|---|

Seneca Companies, Inc.
4140 East 14th Street PO Box 3360
Des Moines, IA 50313

Contact Person: Keri Hankins
Phone: (816) 761-1270
Contractor Registration # IL598 Exp. 2/23/2020

Sincerely,



Daniel H. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File