



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

<b>FOR OFFICE USE ONLY</b> Facility # 5011988 Permit # 02144-2019REM Request Rec'd 11/04/2019 Amended Date Approval Date 11/7/2019 DS Permit Expires 5/7/2020
---

**Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Illinois Department of Transportation 2300 S. Dirksen Parkway Springfield, IL 62764</p> <p>Contact: Amy Eller (217) 557-2070</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Dist 6 Operations 5204 Old Route 36 Springfield, IL 62707</p> <p>Contact: Mark Esker (217) 782-1449</p>
--	---

**(3) REMOVAL OF PIPING:**

- (a) Description/location of piping being removed:*
- (b) Which tank(s) are associated with the piping being removed: (TK # 1, 2) - 9,400*
- (c) Reason of piping being removed:*
- (d) If piping is leaking, indicate IEMA incident number:*

**(4)** After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

**(5) SPECIAL CONTINGENCIES :**

Remove the existing singlewall product piping. The concrete over the tanks will be removed and the existing piping will be removed and new piping installed under a separate upgrade permit. The spill buckets and overflow drop tubes on tanks 1 & 2 will be replaced under a like for like permit or if the existing drop tubes cannot be removed and requires new risers to be installed I will amend permit #02120-2019UPG to include the new risers, spill buckets and overflow drop tubes.

**NOTE: Please see contingencies above that will address the active N.O.V.**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
<p>UPC Enterprises, LC d/b/a United Petroleum Service 4444 Union Blvd. St. Louis, MO 63115</p>	<p>Contact Person: Harvey Stokes Phone: (314) 241-3767 Contractor Registration # IL002402 Exp. 2/10/2020</p>

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File