



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2001716
Permit # 02191-2019UPG
Request Rec'd 11/17/2019
Amended Date
Approval Date 11/18/2019 DS
Permit Expires 5/19/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Mount Prospect Road Properties, LLC 250 East Touhy Des Plaines, IL 60018 Contact: Bob Sieverding (847) 298-0360	(2) <u>FACILITY</u> - name and address where tanks are located: Lorig Construction Co., d/b/a Lorig Mount Prospect Yard 2100 S. Mt. Prospect Rd. Des Plaines, IL 60018 Contact: Bob Sieverding (847) 298-0360
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3) - 12,000, (TK # 4) - 3,000, (TK # 8) - 5,000*
- (b) *Type of tanks:*
- (c) *Type of piping:*
- (d) *Product to be stored in each tank: (TK # 1) - Dyed Diesel, (TK # 2, 3) - Diesel Fuel, (TK # 4) - Gasoline - Regular, (TK # 8) - Used Oil*
- (e) *Type of leak detection being used:*
- Tank: (TK # 1, 2, 3, 4, 8) Leak Detect - Tank - Automatic Tank Gauging Ommtec Proteus-K (OEL8000IIHK8)*
- Piping:*
- (f) *Corrosion Protection being used:*
- Tank:*
- Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : Installing new Ommtec Proteus tank monitor with (5) tank testing probes.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Metro Environmental Contractors, Inc. dba Metro Tank & Pump Company
1111 West Dundee Road
Wheeling, IL 600903936

Contact Person: Warren Cherner
Phone: (847) 465-4000
Contractor Registration # IL102 Exp. 9/20/2021

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File