



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 1034915
Permit # 02121-2019UPG
Request Rec'd 11/04/2019
Amended Date 12/03/2019 DS
Approval Date 11/4/2019 DS
Permit Expires 5/5/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Kelley Williamson Company 1132 Harrison Avenue Rockford, IL 61104 Contact: Bob Sanders (815) 397-9410</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Belvidere Mobil Mart 1776 Logan Ave Belvidere, IL 61008 Contact: Amy Sayles (815) 397-9410</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 3, 4) - 8,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 4) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX to accomodate dispenser being moved a short distance*
- (d) Product to be stored in each tank: (TK # 3) - Gasoline, (TK # 4) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 3, 4) Spill Contain Device - Double Wall Spill Bucket*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Installation of new canopy over diesel island. Diesel island will need to move a couple feet North to make room for the canopy footing. Existing double wall fiberglass LCX pipe will be extended to reach a new fiberglass dispenser sump. Existing dispenser will be installed on the new sump.

NOTE: Existing leak detection and sensors to be re-used

Amendment Reason: Spill buckets and manholes on tanks 3 & 4 will be replaced. Existing manholes will be disturbed during some concrete replacement.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Oil Equipment Company, Inc.
4701 Lien Road
Madison, WI 53704

Contact Person: TJ Winkler
Phone: (608) 249-2881
Contractor Registration # IL1318 Exp. 10/29/2020

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File