



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 1017927
Permit # 02272-2019UPG
Request Rec'd 12/04/2019
Amended Date
Approval Date 12/4/2019 DS
Permit Expires 6/4/2020

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Johnson Oil Company 1305 12th Avenue Rock Falls, IL 61071 Contact: Kathy Peugh (815) 625-6380	(2) FACILITY - name and address where tanks are located: Johnson Oil Co. 8120 Illinois Route 2 South Grand Detour, IL 61021 Contact: Kendra Barnhart (815) 625-6380
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1) - 10,000, (TK # 2) - 6,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 1) - Gasoline - Regular, (TK # 2) - Gasoline - Premium*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices: (TK # 1, 2) Overfill Prev Device - Overfill Alarm Incon TS-RAI*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

installing overfill alarm, both tanks. Will also be removing the overfill prevention drop tubes


NOTE: No ball floats existing

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Illowa Enterprises, Inc.
2703 4th Avenue
Moline, IL 61265

Contact Person: Rob Vyncke
Phone: (309) 762-1729

Sincerely,



Daniel H. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File