



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 7011108  
Permit # 02315-2019ENT  
Request Rec'd 12/10/2019  
Amended Date  
Approval Date 12/10/2019 DS  
Permit Expires 6/10/2020

**Permit for HOTWORK/ ENTRY into Underground Storage Tank(s) for Petroleum and Hazardous Substances.**

Permission to enter underground storage tank(s) is hereby granted. Such tank entry shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Moto, Inc. 721 W. Main Street P.O. Box 0122 Belleville, IL 62222</p> <p>Contact: Rob Whittington (618) 233-6754 Ext. 106</p>	<p>(2) <b>FACILITY</b> - name and address where tanks are located:</p> <p>Olney Moto Mart 1221 South West Street Olney, IL 62450</p> <p>Contact: Rob Whittington (618) 233-6754 Ext. 106</p>
--	--

(3) **ENTRY OF TANKS:**

- (a) *Number and size of tanks being entered: (TK # 1) - 12,000*
- (b) *Type of tanks:*
- (c) *Product to be stored in each tank: (TK # 1) - Diesel Fuel*
- (d) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank entry has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling 2177851020.

(5) **SPECIAL CONTINGENCIES** : Tank relining, lining inspection and entry permit work in reference to manways/manholes must abide by section 175.500. The diesel tank will be closed in place per State and Federal regulations. Entry into the tank is needed to remove residual product and clean before filling with material.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Hinderliter Construction & Maint., Inc.  
3601 North St. Joseph Avenue  
Evansville, IN 47720

Contact Person: Mark Hinderliter  
Phone: (812) 425-4137  
Contractor Registration # IL646 Exp. 4/2/2020

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File