



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**Amended**

**FOR OFFICE USE ONLY**

Facility # 2046923  
Permit # 01703-2019INS  
Request Rec'd 09/09/2019  
Amended Date 12/12/2019 DS  
Approval Date 9/10/2019 DS  
Permit Expires 3/10/2020

**Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Roundy's Supermarket, Inc. A division of the Kroger Co. 875 E. Wisconsin Ave. Milwaukee, WI 53202</p> <p>Contact: Shaun Nelson (414) 231-5880</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Mariano's 1300 E. Illinois Route 22 Lake Zurich, IL 60047</p> <p>Contact: Shaun Nelson (414) 231-5880</p>
--	--

**(3) INSTALLATION OF TANKS:**

- (a) *Number and size of tanks being installed: (TK # 1) - 20,000, (TK # 2) - 10,000, (TK # 3) - 8,000*
- (b) *Type of tank(s): (TK # 1, 2, 3) Tank - Fiberglass Brine Filled Double Wall XERXES*
- (c) *Type of piping: (TK # 1, 2, 3) Piping - Fiberglass Single Wall Piping Ameron 4000 L single wall vent piping, (TK # 1, 2, 3) Piping - Flexible Double Wall OPW Flexworks product piping from tanks to dispensers as shown in site drawing, (TK # 1, 2, 3) Piping - Ball Valves, (TK # 1, 2, 3) Piping - Shear Valves, (TK # 1, 2, 3) Piping - Flex Connector Steel, (TK # 1, 2, 3) Piping - Single Wall STP/Tanktop Sump XERXES Fiberglass*
- (d) *Product to be stored in each tank: (TK # 1) - Gasoline - Regular, (TK # 2) - Diesel Fuel, (TK # 3) - Gasoline - Premium*
- (e) *Type of leak detection being used:*
- Tank: (TK # 1, 2, 3) Leak Detect - Tank - Automatic Tank Gauging Incon TS 550 with SCALD, (TK # 1, 2, 3) Leak Detect - Tank - Hydrostatic Reservoir Sensors Interstitial Monitoring Incon TSP-UHS*
- Piping: (TK # 1, 2, 3) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Incon TS-LS500E, (TK # 1, 2, 3) Leak Detect - Piping - Non-Discriminating Sump Sensor Incon in all submersible and dispenser sumps*
- NOTE: Sensors must shut down the submersible pump supplying that line upon detection of a leak per 175.640 a) 1)*
- (f) *Corrosion Protection being used:*
- Tank: (TK # 1, 2, 3) Corrosion Prot - Tank - Fiberglass Non-Corrosive*
- Piping: (TK # 1, 2, 3) Corrosion Prot - Piping - Fiberglass Non-Corrosive*
- (g) *Spill containment devices, piping and dispenser containment devices: (TK # 1, 2, 3) Spill Contain Device - Double Wall Spill Bucket OPW 1C-3132D Edge*
- (h) *Overfill prevention devices: (TK # 1, 2, 3) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-410C, (TK # 1, 2, 3) Overfill Prev Device - Overfill Alarm Incon TS-RA1*

(4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **GENERAL REQUIREMENTS** : There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight

containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

**(6) SPECIAL CONTINGENCIES :**


Amendment Reason: Diesel tank size is incorrect.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Stenstrom Petroleum Services Group  
2422 Center Street  
Rockford, IL 61108

Contact Person: Robert Stenstrom  
Phone: (815) 398-6250  
Contractor Registration # IL1890 Exp. 4/12/2020

Sincerely,



Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File