



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

FOR OFFICE USE ONLY  
Facility # 2-001797  
Permit # 01316-2012UPG  
Request Rec'd 12/19/2012  
Amended Date  
Approval Date 12/20/2012 JC  
Permit Expires 6/20/2013

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Village of Broadview 2400 S. 25th Avenue Broadview, IL 60153-4091 Contact: Tierney Chief (708) 343-6124	<b>(2) FACILITY</b> - name and address where tanks are located: Broadview Fire Dept 2400 S. 25th Street Broadview, Cook Co., IL Contact: Tierney Chief (708) 343-6124
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1) - 10,000 gallons, (TK # 2) - 4,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 1, 2) - (Installing) Tank Sumps containment FRP, (TK # 1, 2) - (Installing) One Dispenser Sump containment FRP, (TK # 1, 2) - (Installing) Fiberglass Double Wall Ameron Dualoy 3000/LCX to replace the existing product piping, (TK # 1, 2) - (Installing) Fiberglass Single Wall Piping Ameron to replace the existing vent piping.
- (d) *Product to be stored in each tank:* (TK # 1) - Gasoline, (TK # 2) - Diesel Fuel
- (e) *Type of leak detection being used:*  
*Tank:* (TK # 1, 2) - (Installing) Automatic Tank Gauging Veeder Root TLS 300c to replace the existing console and probes.  
*Piping:* (TK # 1, 2) - (Installing) European with No Test Req Suction (note: section 175.640(b)(2)(E) must be referenced for European suction, for present and future verification).
- (f) *Corrosion Protection being used:*  
*Tank:*  
*Piping:* (TK # 1, 2) - (Installing) Fiberglass Non-Corrosive product and vent piping.
- (g) *Spill containment devices, piping, and dispenser containment devices:* (TK # 1, 2) - (Installing) Manhole Pre-manufactured EBW 705
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES:**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>  Lyons, IL 60534	Contact Person: Thomas J JR Doherty Phone: (708) 579-9189 Ext.  Contractor Registration # Exp.
--	---

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -  
Fire Department -  
Office Coordinator -  
Division File  
(Rev. - 9/10)