

## OFFICE OF THE ILLINOIS STATE FIRE MARSHAL Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

## FOR OFFICE USE ONLY

Facility # 2-043963
Permit # 00319-2008INS
Request Rec'd 02/27/2008
Amended Date
Approval Date 3/7/2008 JC
Permit Expires 9/7/2008

## Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Rohm and Haas Chemical LLC 1400 Harvard Drive Kankakee, IL 60901	Rohm and Haas Chemical LLC 1400 Harvard Drive Kankakee, Kankakee Co., IL
Contact:	Contact:

## (3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 1, 2) 50,000 gallons
- (b) Type of tanks: (TK # 1, 2) (Installing) ACT 100 double wall composite
- (c) Type of piping: (TK # 1, 2) (Installing) All product piping will be above ground single wall steel
- (d) Product to be stored in each tank: (TK # 1, 2) Hazardous Substance (Butyl Acrylate, and 2 Ethyl Hexyl Acrylate)
- (e) Type of leak detection being used:

Tank: (TK # 1, 2) - (Installing) Pneumercator TMS3000 interstitial tank sensor

*Piping:* (TK # 1, 2) - (Installing) All product piping will be above ground.

(f) Corrosion Protection being used:

Tank: (TK # 1, 2) - (Installing) Composite

*Piping:* (TK # 1, 2) - (Installing) All product piping will be above ground steel.

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at <a href="https://www.state.il.us/osfm">www.state.il.us/osfm</a> or by calling (217)785-1020.
- (5) GENERAL REQUIREMENTS:
- (6) **SPECIAL CONTINGENCIES**:

(7) PERSON, FIRM OR COMPANY PERFORMING WORK:	Contact Person: Steve Twiddy Phone:	
	Contractor Registration # IL-1808	Exp. 10/26/2008

Janu J Coffey

Sincerely,

cc: Storage Tank Safety Specialist -Fire Department -

> Office Coordinator -Division File

(Rev. - 1/98)

Sincercity,