

OFFICE OF THE ILLINOIS STATE FIRE MARSHAL Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

FOR OFFICE USE ONLY

Facility # 2-042924
Permit # 00295-2008INS
Request Rec'd 03/05/2008
Amended Date
Approval Date 3/5/2008 JC
Permit Expires 9/5/2008

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Mohar Company 1260 Winnetka St Palatine, IL 60067	Zion Crossings Route 173 & Green Bay Rd Zion, Lake Co., IL
Contact: Mohinder Singh (847) 293-3122	Contact: Mohinder Singh (847) 293-3122

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 1) 20,000 gallons, (TK # 3) 6,000 gallons, (TK # 5) 10,000 gallons
- (b) Type of tanks: (TK # 1, 3, 5) (Installing) Containment Solutions single wall fiberglass
- (c) Type of piping: (TK # 1, 3, 5) (Installing) A.O. Smith double wall fiberglass
- (d) Product to be stored in each tank: (TK # 1, 5) Gasoline, (TK # 3) Diesel Fuel
- (e) Type of leak detection being used:

Tank: (TK # 1, 3, 5) - (Installing) Veeder Root TLS350j with CSLD automatic tank gauge

Piping: (TK # 1, 3, 5) - (Installing) Veeder Root TLS350j electronic line leak detector, (TK # 1, 3, 5) - (Installing) Veeder Root TLS350j interstitial piping sump sensor at all dispenser sumps only.

(f) Corrosion Protection being used:

Tank: (TK # 1, 3, 5) - (Installing) Fiberglass **Piping:** (TK # 1, 3, 5) - (Installing) Fiberglass

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.
- (5) GENERAL REQUIREMENTS:
- (6) SPECIAL CONTINGENCIES:

(/	/)	PERSON.	, FIKM	OK COMP	ANY PERF	ORMING	WORK:
•	_						

Contact Person: Kevin Krohn

Phone:

Contractor Registration # IL-1175 Exp. 03/04/2010

Sincerely,

cc: Storage Tank Safety Specialist -

Fire Department - Office Coordinator -

Division File

(Rev. - 1/98)

Janu J Offey