



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Technical Services**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)524-7605

<b>FOR OFFICE USE ONLY</b>
Facility # 2-025082
Permit # 00283-2008UPG
Request Rec'd 02/25/2008
Amended Date
Approval Date 2/29/2008 JC
Permit Expires 8/29/2008

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:          Gas City, Ltd.          160 South LaGrange Road          Frankfort, IL 60423          Contact: Len McEnergy (815) 469-9000</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:          Gas City          2700 W 147St          Posen, Cook Co., IL          Contact: Len Mcenergy (815) 469-9000</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1) - 8,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 1) - (Installing) Steel flex connector to replace the existing leaking flex connector approximately 3' away from dispenser #3 / #4 (north side), (TK # 1) - (Installing) short section of single wall fiberglass piping to repair a short leaking section along with replacing the above mentioned flex connector.
- (d) *Product to be stored in each tank:* (TK # 1) - Gasoline
- (e) *Type of leak detection being used:*  
     *Tank:*  
     *Piping:*
- (f) *Corrosion Protection being used:*  
     *Tank:*  
     *Piping:* (TK # 1) - (Installing) short section of fiberglass (TK # 1) - (Installing) flex connector isolation boot for the new flex connector
- (g) *Spill containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES:** Tank #1 is the regular unleaded tank which is located closest to the building in the tank field (tank #2 is the premium tank located in the middle of the tank field).

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p>	<p>Contact Person: Doug Harmon          Phone: (708) 758-3222          Contractor Registration # IL-194 Exp.</p>
--	--

Sincerely,

*James J. Coffey*

