



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

Amended

FOR OFFICE USE ONLY
Facility # 2-015576
Permit # 00142-2008UPG
Request Rec'd 01/29/2008
Amended Date 02/22/2008
Approval Date 1/29/2008 JC
Permit Expires 7/29/2008

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Bill Stasek Chevrolet, Inc. 700 W. Dundee Road Wheeling, IL 60090 Contact: Harold "Hub" Hubbard	(2) FACILITY - name and address where tanks are located: Bill Stasek Chevrolet, Inc. 700 W. Dundee Road Wheeling, Cook Co., IL Contact: Harold "Hub" Hubbard
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired:* (TK # 6) - 6,000 gallons, (TK # 7) - 1,000 gallons
- (b) Type of tanks:* (TK # 6, 7) - Existing double wall fiberglass brine filled
- (c) Type of piping:* (TK # 6, 7) - Existing double wall fiberglass
- (d) Product to be stored in each tank:* (TK # 6) - Gasoline, (TK # 7) - Used Oil
- (e) Type of leak detection being used:*
 - Tank:** (TK # 6, 7) - (Installing) OPW EECO 1500 hydrostatic interstitial tank sensor for tank leak detection, (TK # 6, 7) - (Installing) OPW EECO 1500 automatic tank gauge console and probes (used for inventory purposes only).
 - Piping:** (TK # 6, 7) - Existing interstitial monitoring to be removed (see contingencies), (TK # 6, 7) - Existing European Suction (see contingencies)
- (f) Corrosion Protection being used:*
 - Tank:** (TK # 6, 7) - Existing fiberglass
 - Piping:** (TK # 6, 7) - Existing fiberglass
- (g) Spill containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.**

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Hajlije Dragovic Phone: (847) 465-4000 Contractor Registration # IL-102 Exp.

Sincerely,

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)