

OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

Amended and revised

FOR OFFICE USE ONLY

Facility # 4-043942 Permit # 00167-2008INS Request Rec'd 01/30/2008

Amended Date 02/22/2008

Approval Date 2/4/2008 JC Permit Expires 8/4/2008

<u>Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.</u>

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Effingham Clay Service Co 410 S Willow St, Box 629 Effingham, IL 62401	Effingham Clay Service Co. Route 16 West Gays, Moultrie Co., IL
Contact: Don Herring (217) 342-9231	Contact:

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed: (TK # 1) 15,000 gallons
- (b) Type of tanks: (TK # 1) (Installing) Containment Solutions single wall fiberglass
- (c) Type of piping: (TK # 1) (Installing) Single wall above ground steel from the tank to the bulk load out rack.
- (d) Product to be stored in each tank: (TK # 1) Soy Oil
- (e) Type of leak detection being used:

Tank: (TK # 1) - (Installing) Veeder Root TLS350 automatic tank gauge for inventory control and tank leak detection

Piping: none required for above ground piping.

(f) Corrosion Protection being used:

Tank: (TK # 1) - (Installing) Fiberglass **Piping: Piping is all above ground steel**

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.
- (5) GENERAL REQUIREMENTS:
- (6) SPECIAL CONTINGENCIES:

(7) <u>PERSON, FIRM OR COMPANY PERFO</u>	<u>ORMING WORK</u>
--	--------------------

Contact Person:

Janu J Coffey

Phone: (309) 347-1819

Contractor Registration # IL-1293 Exp.

Sincerely,

cc: Storage Tank Safety Specialist -

Fire Department - Office Coordinator -

Division File

(Rev. - 1/98)