



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Technical Services**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)524-7605

<b>FOR OFFICE USE ONLY</b>
Facility # 6-020753
Permit # 00219-2008UPG
Request Rec'd 01/15/2008
Amended Date
Approval Date 2/19/2008 JC
Permit Expires 8/19/2008

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:          C-Fab Motor Sports, Inc.          P.O. Box 336          Centralia, IL 62801          Contact: Mike Cooksey</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:          C-Fab Motor Sports, Inc.          304 N. Poplar          Centralia, Marion Co., IL          Contact: Mike Cooksey</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) **Number and size of tanks being upgraded or repaired:** (TK # 9, 10) - 12,000 gallons, (TK # 11) - 10,000 gallons
- (b) **Type of tanks:**
- (c) **Type of piping:** (TK # 9, 10, 11) - Existing single wall fiberglass, (TK # 9, 10, 11) - (Installing) partial A.O. Smith single wall fiberglass to accommodate a brand new row of dispensers (the new piping will extend from the existing trunk line to the new dispensers). The existing islands at this site will have new sumps installed, and new dispensers installed (the new sections of piping for these existing islands will be relatively short sections of piping in the localized area to accommodate the new sumps and dispensers).
- (d) **Product to be stored in each tank:** (TK # 9, 10) - Gasoline, (TK # 11) - Diesel Fuel
- (e) **Type of leak detection being used:**  
     **Tank:**  
     **Piping:**
- (f) **Corrosion Protection being used:**  
     **Tank:**  
     **Piping:**
- (g) **Spill containment devices:**
- (h) **Overfill prevention devices:**
- (i) **Manway accessible at grade:**

(4) **The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES:**

<p><b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p> <p align="right">Contact Person: Joe Richmond          Phone: 812-424-0014          Contractor Registration #    Exp.</p>
--

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -  
 Fire Department -  
 Office Coordinator -  
 Division File

