

OFFICE OF THE ILLINOIS STATE FIRE MARSHAL Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

FOR OFFICE USE ONLY

Facility # 2-008988
Permit # 00176-2008UPG
Request Rec'd 02/04/2008
Amended Date
Approval Date 2/4/2008 JC
Permit Expires 8/4/2008

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE**.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other

business entity:

Exxon Mobil Oil Corporation

7300 West Friendly Avenue, P.O. Box 22087, CMS Mailstop F-76

Croonahar

Greensboro, NC 27420-2087

Contact: Eric McPhee (800) 253-8054

(2) **FACILITY** - name and address where tanks are located:

Mobil SS #05BB9 1333 Half Day Road Highland Park, Lake Co., IL

Contact: Wenda Meadows (708) 432-2208

(3) <u>UPGRADE OR REPAIR OF TANKS:</u>

- (a) Number and size of tanks being upgraded or repaired: (TK # 4) 8,000 gallons
- (b) Type of tanks:
- (c) Type of piping: (TK # 4) (Installing) replacing steel flex connector under dispenser #1 / #2, (TK # 4) (Installing) partial Ameron single wall fiberglass section to repair a damaged section of piping in front of dispenser #1 / #2.
- (d) Product to be stored in each tank: (TK # 4) Gasoline
- (e) Type of leak detection being used:

Tank:

Piping:

(f) Corrosion Protection being used:

Tank:

Piping: (TK # 4) - (Installing) partial fiberglass (TK # 4) - (Installing) Flex connector isolation boot

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (i) Manway accessible at grade:
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

James of Coffey

(5) **SPECIAL CONTINGENCIES**:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Contact Person: Doug Harmon Phone: (708) 758-3222

Contractor Registration # IL-194 Exp.

Sincerely,

cc: Storage Tank Safety Specialist -

Fire Department -

Office Coordinator -

Division File

(Rev. - 1/98)