



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

Amended

FOR OFFICE USE ONLY
Facility # 3-018952
Permit # 02069-2007INS
Request Rec'd 12/11/2007
Amended Date 01/31/2008
Approval Date 12/11/2007 JC
Permit Expires 6/11/2008

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Triple Crown Fuels, Inc. 1314 Norma Drive Bloomington, IL 61704 Contact: Alex Alom	(2) FACILITY - name and address where tanks are located: Princeville Fast Stop 615 E. Main Street Princeville, Peoria Co., IL Contact: Mike Hassan (309) 385-4308
--	--

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed:** (TK # 6) - 12,000 gallons
- (b) Type of tanks:** (TK # 6) - (Installing) Containment Solutions double wall fiberglass brine filled
- (c) Type of piping:** (TK # 6) - Existing partial non-corrosive flexible from existing transition sump to the existing islands, (TK # 6) - (Installing) partial - approximately 40' of A.P.T. Poly Tech P175 SC double wall flexible from the submersible to the existing transition sump.
- (d) Product to be stored in each tank:** (TK # 6) - Gasoline
- (e) Type of leak detection being used:**
 - Tank:** (TK # 6) - (Installing) EBW Auto Stik LS-30A interstitial tank sensor for tank leak detection, (TK # 6) - Existing automatic tank gauging console and probe to be re-used for inventory purposes only.
 - Piping:** (TK # 6) - (Installing) EBW LS-3A interstitial piping sump sensor at the submersible sump only, (TK # 6) - (Installing) Red Jacket FX1V mechanical line leak detector
- (f) Corrosion Protection being used:**
 - Tank:** (TK # 6) - (Installing) Fiberglass
 - Piping:** (TK # 6) - (Installing) Non-corrosive flexible, (TK # 6) - Existing non-corrosive flexible
- (g) Spill containment devices:**
- (h) Overfill prevention devices:**

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.**

(5) GENERAL REQUIREMENTS:

(6) SPECIAL CONTINGENCIES:

(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Contact Person: Phone: (309) 347-1819 Contractor Registration # IL-1293 Exp.
--

Sincerely,