



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-017203
Permit # 00148-2008UPG
Request Rec'd 01/29/2008
Amended Date
Approval Date 1/29/2008 JC
Permit Expires 7/29/2008

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: WRB II Enterprises, Inc. 8755 W. 79th Street Justice, IL 60458 Contact: William R. Beahan II (708) 341-4207	(2) FACILITY - name and address where tanks are located: Justice Citgo 8755 W. 79th Street Justice, Cook Co., IL Contact: William R Beahan II (708) 341-4207
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired:* (TK # 1) - 8,300 gallons, (TK # 2) - 10,000 gallons, (TK # 3, 4) - 6,000 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:* (TK # 1, 2, 3, 4) - (Installing) partial A.P.T. Poly Tech P175 SC double wall flexible from the two existing eastern most dispensers islands to the two new dispenser islands that will be directly east of the existing islands, (TK # 1, 2, 3, 4) - Existing partial non-corrosive flexible for the remainder of product piping, (TK # 1, 2, 3, 4) - (Installing) partial single wall fiberglass vent piping to extend and relocate the existing vent terminal ends to the south side of the building.
- (d) *Product to be stored in each tank:* (TK # 1, 2, 3, 4) - Gasoline
- (e) *Type of leak detection being used:*
Tank:
Piping:
- (f) *Corrosion Protection being used:*
Tank:
Piping:
- (g) *Spill containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: John Meck Phone: (708) 974-1200 Contractor Registration # IL-526 Exp.
--

Sincerely,

