

OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

FOR OFFICE USE ONLY

Facility # 1-005867 Permit # 00102-2008UPG Request Rec'd 01/17/2008 Amended Date Approval Date 1/17/2008 JC Permit Expires 7/17/2008

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:
Casey's Retail Company One Convenience Boulevard, P.O. Box 3001 Ankeny, IA 50021-8045	Casey's General Store #2666 2005 IL Rt 84 South Thomson, Carroll Co., IL
Contact: Jill Reams-Widder (515) 965-6231	Contact: Jill Reams-Widder (515) 965-6231

(3) <u>UPGRADE OR REPAIR OF TANKS:</u>

- (a) Number and size of tanks being upgraded or repaired: (TK # 8) 8,000 gallons
- (b) Type of tanks:
- (c) Type of piping: (TK # 8) (Installing) Steel flex connector and repairing a leak in the vent line. Leak is around the first canopy column where the 90 degree elbow comes out of column. It had a small hole in the bottom side of the elbow fitting. It is below ground at the column subset.
- (d) Product to be stored in each tank: (TK # 8) Gasoline
- (e) Type of leak detection being used:

Tank:

Piping:

(f) Corrosion Protection being used:

Tank:

Piping:

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (i) Manway accessible at grade:
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

Janu J Coffey

(5) **SPECIAL CONTINGENCIES**:

(6) PERSON, FIRM OR COMPANY PERFORMING WO	ORK	W	G	IN	MI	DR	F	PER	Y	A١	AP.	10	CO	OR	M	TR	N.	RSO	PEI	(6)
-------------------------------------------	-----	---	---	----	----	----	---	-----	---	----	-----	----	----	----	---	----	----	-----	-----	-----

Contact Person: Art Wentworth

Phone: (563) 344-0700

Contractor Registration # IL-2034 Exp.

Sincerely,

cc: Storage Tank Safety Specialist -

Fire Department -

Office Coordinator -Division File

(Rev. - 1/98)