



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020

FOR OFFICE USE ONLY
Facility # 3-043850
Permit # 01288-2012CAT
Request Rec'd 12/07/2012
Amended Date
Approval Date 12/7/2012 JC
Permit Expires 6/7/2013

Permit for INSTALLATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. A required job schedule for cathodic protection upgrade of underground storage tank(s) and piping must be submitted to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Sullivans Fuels (Foods) 425 First Street Savanna, IL 61074 Contact: Mike Sullivan (815) 273-4511	(2) FACILITY - name and address where tanks are located: Sullivan Foods 605 Tenney Street Kewanee, Henry Co., IL Contact: John Hill (309) 853-1600
--	---

(3) , UPGRADE, OR REPAIR OF CATHODIC PROTECTION SYSTEM:

- (a) *Number and size of tanks having cathodic protection installed, upgraded, or repaired:* (TK # 1) - 15,000 gallons, (TK # 2) - 7,500 gallons
- (b) *Type of tanks:*
- (c) *Type of piping:*
- (d) *Product to be stored in each tank:* (TK # 1) - Gasoline, (TK # 2) - E-85
- (e) *Type of leak detection being used:*
Tank:
Piping:
- (f) *Corrosion Protection being used:*
Tank:
Piping: (TK # 1, 2) - (Installing) Sacrificial Anode Flex Connector anodes for the flex connectors and / or other exposed metallic fittings or components at the submersible sumps only.
- (g) *NACE certified designer:* Gilbert Schutza *Certification number:* 4108
- (h) *Method of integrity assessment of tank(s) being used:*

- (4) The owner must notify this Office when completion of cathodic protection upgrade has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for cathodic protection upgrade to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: Elgin, IL 60123	Contact Person: Milly Morales Phone: (847) 888-4836 Contractor Registration # Exp.
--	--

Sincerely,

Jim Coffey

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 9/10)