

OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Division of Technical Services

1035 Stevenson Drive Springfield, Illinois 62703-4259 (217)524-7605

FOR OFFICE USE ONLY

Facility # 2-034514
Permit # 00030-2008UPG
Request Rec'd 01/04/2008
Amended Date
Approval Date 1/4/2008 JC
Permit Expires 7/4/2008

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

ALL ROYAL DATE.					
(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:	(2) <u>FACILITY</u> - name and address where tanks are located:				
Thornton Oil Corp. 10101 Linn Station Road, P.O. Box 34230 Louisville, KY 40223	Thornton Oil Corp #121 2401 63rd Street Woodridge, Du Page Co., IL				
Contact: E Zoph (800) 928-8022	Contact: Mgr (708) 271-0020				

(3) <u>UPGRADE OR REPAIR OF TANKS:</u>

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3) 12,000 gallons, (TK # 4, 5) 6,000 gallons
- (b) Type of tanks:
- (c) Type of piping: (TK # 1, 2, 3, 4, 5) Existing single wall fiberglass to be modified under shear valves to accommodate new dispensers. The dispenser locations will remain unchanged.
- (d) Product to be stored in each tank: (TK # 1, 2, 3) Gasoline, (TK # 4) Diesel Fuel, (TK # 5) Kerosene
- (e) Type of leak detection being used:

Tank:

Piping:

(f) Corrosion Protection being used:

Tank:

Piping: (TK # 1, 2, 3, 4, 5) - Existing containment sumps to be shortened to accommodate new dispensers.

- (g) Spill containment devices:
- (h) Overfill prevention devices:
- (i) Manway accessible at grade:
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

Janu J Coffey

(5) **SPECIAL CONTINGENCIES**:

(b)	PERSON.	, FIRM OR	k COMPANY	PERFORMING	WORK:

Contact Person: Keith Davis Phone: (630) 530-9880

Contractor Registration # IL-1733 Exp.

Sincerely,

cc: Storage Tank Safety Specialist -

Fire Department - Office Coordinator -

Division File

(Rev. - 1/98)