



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-006942
Permit # 02115-2007INS
Request Rec'd 12/19/2007
Amended Date
Approval Date 12/20/2007 JC
Permit Expires 6/20/2008

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for installation of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Shell Oil Products US 7300 West Friendly Avenue, P.O. Box 22087, Attn: CMS Mailstop F-76 Greensboro, NC 27420-2087 Contact: Michael Lewis (800) 253-8054	(2) FACILITY - name and address where tanks are located: Shell Station 4944-02 4755 Vollmer and Cicero Matteson, Cook Co., IL Contact: Timothy Lowery (815) 577-8515
---	---

(3) INSTALLATION OF TANKS:

- (a) Number and size of tanks being installed:** (TK # 4) - 20,000 gallons, (TK # 5) - 12,000 gallons, (TK # 6) - 8,000 gallons
- (b) Type of tanks:** (TK # 4, 5, 6) - (Installing) XERXES double wall fiberglass brine filled
- (c) Type of piping:** (TK # 4, 5, 6) - (Installing) Universal Petro Pipe double wall non-corrosive flexible
- (d) Product to be stored in each tank:** (TK # 4, 5) - Gasoline, (TK # 6) - Diesel Fuel
- (e) Type of leak detection being used:**
 - Tank:** (TK # 4, 5, 6) - (Installing) Veeder Root TLS 350 with CSLD automatic tank gauge, (TK # 4, 5, 6) - (Installing) Veeder Root TLS 350 hydrostatic reservoir sensor
 - Piping:** (TK # 4, 5, 6) - (Installing) Beaudreau EOS 100 interstitial piping sump sensors at all dispenser sumps and all submersible sumps, (TK # 4, 5, 6) - (Installing) Veeder Root TLS350 electronic line leak detector
- (f) Corrosion Protection being used:**
 - Tank:** (TK # 4, 5, 6) - (Installing) Fiberglass
 - Piping:** (TK # 4, 5, 6) - (Installing) Non-corrosive flexible
- (g) Spill containment devices:**
- (h) Overfill prevention devices:**

- (4) The owner must notify this Office when completion of tank installation has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for installation to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.**

(5) GENERAL REQUIREMENTS:

(6) SPECIAL CONTINGENCIES:

(7) PERSON, FIRM OR COMPANY PERFORMING WORK: Contact Person: Doug Harmon Phone: Contractor Registration # IL-194 Exp. 06/21/2008
--

Sincerely,

cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)