



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)785-1020

FOR OFFICE USE ONLY  
Facility # 2-021849  
Permit # 01274-2012UPG  
Request Rec'd 12/04/2012  
Amended Date  
Approval Date 12/5/2012 DS  
Permit Expires 6/5/2013

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:  Village of Libertyville 118 W Cook Ave Libertyville, IL 60048  Contact: Dave Barker (847) 918-2072	<b>(2) FACILITY</b> - name and address where tanks are located:  Village of Libertyville 600 N Ave Libertyville, Lake Co., IL  Contact: Steve Elliott (847) 362-3434
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired:* (TK # 6, 7) - 10,000 gallons

(b) *Type of tanks:*

(c) *Type of piping:* (TK # 6, 7) - (Installing) Fiberglass Double Wall A.O. Smith from existing tanks to new dispensers., (TK # 6, 7) - (Installing) Dispenser Sumps containment FRP

(d) *Product to be stored in each tank:* (TK # 6) - Diesel Fuel, (TK # 7) - Gasoline

(e) *Type of leak detection being used:*

*Tank:*

*Piping:* (TK # 6, 7) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 in new dispenser sumps, sensors already exist in submersible sumps

(f) *Corrosion Protection being used:*

*Tank:*

*Piping:* (TK # 6, 7) - (Installing) Fiberglass Non-Corrosive

(g) *Spill containment devices, piping, and dispenser containment devices:* (TK # 6, 7) - (Installing) Manhole Pre-manufactured OPW 1-2100

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES:**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>  Plainfield, IL 60544	Contact Person: Gerald Ford Phone: (815) 230-3040  Contractor Registration # Exp.
---	--

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist -  
Fire Department -  
Office Coordinator -  
Division File  
(Rev. - 9/10)