



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)524-7605

FOR OFFICE USE ONLY
Facility # 2-043810
Permit # 02068-2007ABN
Request Rec'd 12/11/2007
Amended Date
Approval Date 12/11/2007 JC
Permit Expires 6/11/2008

Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: United Investors, Inc. 5948 North Broadway Chicago, IL 60660 Contact: Dimirtius Konstantopoulos (773) 989-0100	(2) FACILITY - name and address where tanks are located: Hubbard Woods Plaza 63-107 Glencoe Road Glencoe, Cook Co., IL Contact:
--	--

(3) ABANDONMENT IN PLACE OF TANKS:

- (a) *Number and size tanks being abandoned:* (TK # 1, 2, 3, 4, 5, 6, 7) - 550 gallons
(b) *Location of tanks being abandoned:* CONTAMINATED SITE! IEMA Number: 071578

- (4) This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.
- (5) **SPECIAL CONTINGENCIES: Permit #01503-2007REM is valid until 03/18/08. Site assessment copy is on file at this office. These tanks are all 2 1/2 feet away from the building foundation and / or within a very close proximity to underground natural gas lines. A large cooler is also located over tank #6 (see enclosed photos and site plan for details).**
- (6) **The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.state.il.us/osfm or by calling (217)785-1020.**

(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u> Environmental Protection Ind 16650 S Canal Street South Holland, IL 60473	Contact Person: George Kobylarcik Phone: (708) 225-1115 Contractor Registration # IL-564 Exp.
---	---

Sincerely,



cc: Storage Tank Safety Specialist -
Fire Department -
Office Coordinator -
Division File
(Rev. - 1/98)