



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL  
Division of Technical Services  
1035 Stevenson Drive  
Springfield, Illinois 62703-4259  
(217)524-7605

FOR OFFICE USE ONLY  
Facility # 4-021684  
Permit # 02025-2007ABN  
Request Rec'd 12/03/2007  
Amended Date  
Approval Date 12/3/2007 JC  
Permit Expires 6/3/2008

**Permit for ABANDONMENT IN PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to abandon in place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Gill, Ajit S. 1601 S. Banker Street Effingham, IL 62401 Contact: Ajit S. Gill	<b>(2) FACILITY</b> - name and address where tanks are located: Click & Go 1601 S. Banker Effingham, Effingham Co., IL Contact: Ajit S. Gill
---	--

**(3) ABANDONMENT IN PLACE OF TANKS:**

*(a) Number and size tanks being abandoned:* (TK # 3) - 6,000 gallons

*(b) Location of tanks being abandoned:*

- (4) This permit is VOID if contamination is revealed during abandonment procedures or if tanks are not as indicated on your granted permit site plan. If contamination is revealed, this abandonment can continue only when the contaminated site section (2) of the certification on site condition has been submitted to our Office.
- (5) **SPECIAL CONTINGENCIES:** Inspector should note there is a discrepancy as to what the exact tank layout is at this site (old permit site plans show tank #3 being positioned on the west side of tanks 1 & 2 as opposed to the current site plan for this permit showing that tank #3 is east of tanks 1 & 2). Tank #3 is in the same tank field as two other active tanks. Removal of this tank has the potential to damage tanks 1 & 2. A conversation with Scott Justice mentioned that the edge of tank #3 is approximately 1 1/2' to 2' away from the end edges of tanks 1 & 2. The piping run for tank #3 is also apparently in the same piping trench as the other active lines; consequently, the line for tank #3 will have to be abandoned in place also. Site assessment copy is on file.
- (6) The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.

<b>(7) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></b> Bolin Enterprises, Inc. P.O. Box 70, Casey, IL 62420	Contact Person: Scott Justice Phone: (217) 932-4533 Contractor Registration # IL-002333 Exp.
--	--

Sincerely,

cc: Storage Tank Safety Specialist -  
Fire Department -  
Office Coordinator -  
Division File  
(Rev. - 1/98)