



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Technical Services
 1035 Stevenson Drive
 Springfield, Illinois 62703-4259
 (217)524-7605

FOR OFFICE USE ONLY
Facility # 2-009067
Permit # 02015-2007UPG
Request Rec'd 11/29/2007
Amended Date
Approval Date 11/30/2007 JC
Permit Expires 5/30/2008

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Part 170. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Sibi Kadalimattom 1701 W Harrison Maywood, IL 60153 Contact: Sibi or Manoj Kadalimattom (708) 343-8705</p>	<p>(2) FACILITY - name and address where tanks are located: Maywood Mart Care 1701 W. Harrison Maywood, Cook Co., IL Contact: Sibi or Manoj Kadalimattom (708) 343-8705</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) **Number and size of tanks being upgraded or repaired:** (TK # 1) - 10,000 gallons, (TK # 2) - 8,000 gallons, (TK # 3) - 6,000 gallons
- (b) **Type of tanks:**
- (c) **Type of piping:** (TK # 1, 2, 3) - Existing partial single wall fiberglass to remain from the tanks to the existing Harrison street side dispenser area, (TK # 1, 2, 3) - (Installing) partial A.O. Smith single wall fiberglass from the existing "Harrison street side" dispenser area to the two new dispensers (the existing island will be removed, and the new piping will connect in the same area and extend to the two new dispensers). New dispensers will also be installed for the two 17th avenue island side; however, there will be no work under the shear valve for those two existing islands. Also, the center mid-grade tank will be converting to diesel fuel.
- (d) **Product to be stored in each tank:** (TK # 1, 2, 3) - Gasoline
- (e) **Type of leak detection being used:**
 Tank:
 Piping: (TK # 1, 2, 3) - (Installing) Veeder Root TLS350 interstitial piping sump sensors at the two new dispenser islands only (Harrison street side), (TK # 1, 2, 3) - Existing line leak detector
- (f) **Corrosion Protection being used:**
 Tank:
 Piping:
- (g) **Spill containment devices:**
- (h) **Overfill prevention devices:**
- (i) **Manway accessible at grade:**

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.state.il.us/osfm or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES:

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p>	<p>Contact Person: Ray Kirchner Phone: Contractor Registration # IL-194 Exp.</p>
--	--

Sincerely,

James J. Coffey

